



25 August 2021

Whom It May Concern;

All United Window & Door Mfg. products have been certified in accordance to the guideline established by AAMA/WDMA/CSA 101/I.S.2./A440 performance standard [North American Fenestration Standard/Specification for windows, doors, and skylights]. Windows are tested and certified on a yearly basis to fulfill the guidelines managed by our Third-party Validation Company NAMI (National Accreditation & Management Institute, Inc.). To properly evaluate the performance of a product and/or the performance of a product as intended, it is important that nationally developed and recognized standards and procedures be used.

- ❖ Our 9600 series Vinyl Double Hung Window have a Class LC-PG35 ratings.
- ❖ Our 9600 series Fixed Window have a Class LC-PG40 rating.

	<u>Window Size</u>	<u>Configuration</u>	<u>AAMA Rating (psf)</u>	<u>Air (cfm/ft2)</u>	<u>Water (psf)</u>
94-9600 Series Window Test	44" x 75"	Double Hung	Class LC-PG35-H	0.11	6.06
94-9600 Series Window Test	40" x 63"	Double Hung	Class LC-PG40-H	0.11	6.06
9640 Window Test	56" x 56"	Fixed	Class LC-PG40-FW	0.07	6.06
9640 Window Test	44" x 75"	Fixed	Class LC-PG40-FW	0.03	6.06

If I can be of further assistance on this question or any other, please contact me.

Sincerely,

Craig Calderone

Craig Calderone,
Director of Engineering